

CERTIFICATE OF ANALYSIS

NY Lab ID 11534

Project Name:	<b>Bolton Central School Distri</b>	Workorder:	<b>C061690</b>
---------------	-------------------------------------	------------	----------------

Kathleen Dennin  
Bolton Central School District  
26 Horicon Avenue  
Bolton Landing, NY 12814

Project Name and Number: **Bolton Central School District**

March 26, 2021

Dear Kathleen Dennin,

This report relates only to the sample(s) as received by the laboratory. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.


If you have any questions in reference to this laboratory report, please contact your CNA Environmental project coordinator or laboratory manager listed at the bottom of this report at (518) 884-0800.

Note: This coverage page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Laboratory Manager

CNA Environmental, LLC



Emily Grattidge, Lead Technical Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

**Client:**

Bolton Central School District  
 26 Horicon Avenue  
 Bolton Landing, NY 12814

**Project:**

Bolton Central School District

CNA Environmental, LLC received the sample(s) associated with this batch in compliance with NYSDOH guidelines. The requested analysis methods and results are detailed in the following data summary reports. Any exceptions to method procedures are listed in the comments section below.

To meet the New York Sanitary Code for Public Drinking Water, Total Coliform must be absent or <1; all other analytes must be less than or equal to the MCL.

**Metals:**

Sample(s) meet the NYSDOH MCL criteria for the parameters shown in the results section.


Exceptions: N/A

**Total Metals**

Date Received: 03/04/21 15:20

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed	Notes
C061690-01	Lead	EPA 200.9	0.001	0.001	mg/L	0.015	Rm 202 Sink	3/4/21 06:55	3/25/21 10:35	ET
C061690-02	Lead	EPA 200.9	ND	0.001	mg/L	0.015	Rm 216 Sink	3/4/21 06:57	3/25/21 10:35	ET

CNA Environmental, LLC



Emily Grattidge, Lead Technical Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*


**Notes and Definitions**

ET	Analysis Performed by NYSDOH ELAP # 10142
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Limit (RL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RL	Reporting Limit-Lowest concentration level that is reportable
MCL/AL	Maximum Contaminant Level*/Action Level
mg/kg wet	Results reported as wet weight
TTL	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

\*MCL values listed in this report are taken from the New York State Department of Health Part 5, Subpart 5-1 Public Water System Tables. A full list of parameters and their associated MCL values can be found on the New York Department of Health’s website, [www.health.ny.gov](http://www.health.ny.gov). Please note that some parameters tested may not have an associated MCL value. In other cases, a listed MCL value may refer to a recommended result limit or result equivalent to another parameter; as is the case for heterotrophic plate count (HPC). HPC results equal to or less than 500 colonies/mL is considered to be equivalent to a measurable free chlorine residual.

All work performed by CNA Environmental, LLC is subject to its terms and conditions of services viewable at our office and our website: [www.cnawater.com/about-us/terms](http://www.cnawater.com/about-us/terms)

CNA Environmental, LLC



Emily Grattidge, Lead Technical Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

